



## CERTIFICATE

No. Z2 082429 0150 Rev. 00

**Holder of Certificate:** Risen Energy Co.,Ltd

Meilin, Ninghai,

315609 Ningbo, Zhejiang

082429, 094163, 101449

PEOPLE'S REPUBLIC OF CHINA

**Production** Facility(ies):

**Certification Mark:** 



Crystalline Silicon Terrestrial Photovoltaic (PV) Modules **Product:** 

Mono-Crystalline Silicon Photovoltaic Module

RSM144-6-xxxBMDG, xxx=360 to 405 in step of 5 Model(s):

RSM132-6-xxxBMDG, xxx=330 to 370 in step of 5 RSM120-6-xxxBMDG, xxx=300 to 340 in step of 5 RSM72-6-xxxBMDG, xxx=340 to 385 in step of 5 RSM60-6-xxxBMDG, xxx=280 to 325 in step of 5 xxx is standing for rated output power at STC

Parameters:

Construction: Framed double glass with Junction box,

Cable and Connectors.

Safety Class: Class II

Maximum System Voltage: 1500V DC

Fire Safety Class: Class A according to UL790

Severity of salt mist test: Level 6

Tested

IEC 61215-1-1(ed.1) according to:

IEC 61215-2(ed.1) IEC 61730-1(ed.2)

IEC 61730-2(ed.2) IEC 61701(ed.2)

IEC 61215-1(ed.1)

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.:

704061802960-00

Valid until:

2024-04-02

Date,

2019-04-03

(Zhulin Zhang)